

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**  
**NEW DELHI- 110001**

No.F6/DFS/MS/School/2021/SZ/ 304

Dated: 5/4/21

**FIRE SAFETY CERTIFICATE**

Certified that the Green Valley International School, 205, Deepak Vihar, Najafgarh, New Delhi-110043, Comprised of ground plus three upper floors, owned/occupied by Green Valley International School was issued Fire Safety Certificate by this department vide letter No F6/DFS/MS/School/2017/SZ/806 Dated 13/12/17. The school building was re-inspected by the officer concerned of this department on dated 30/03/2021 in the presence of Sh. Omparkash Gautam (Manager) and found that the School have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service rules 2010, that the building is fit for occupancy Group B 'Educational Building' with effect from

5/4/21 for a period of three years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 5/4/21 at New Delhi by



(Sunil Chawdhary)  
Dy. Chief Fire Officer

Copy to:-

**1. The Principal**

Green Valley International School,  
205, Deepak Vihar, Najafgarh, New Delhi-110043.

  
**MANAGER**

Green Valley International Public School  
(Recognised & Affiliated to CBSE)  
205, Deepak Vihar, Najafgarh, New Delhi-110043.

**2. Director of Education,**

Govt. of N.C.T. Delhi, Old Secretariat, New Delhi-54.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.